

	Units	QUALITY		Test Method
		Typical Value	Specification	
Viscosity @ 40°C	cSt cSt	2.5	5.5 max 1.5 min	BS 2000-71 BS 2000-71
Carbon residue (micro), 10% bottoms	%m/m	< 0.1	0.3 max	BS 2000 -398
Distillation Rec @ 250°C Rec @ 350°C	%v/v %v/v	55 90	65 max 85 min	BS 2000 -123
Flash Point (PMCC)	°C	65 50	56 min	BS 2000 -34
Water Content	mg/kg	< 5	200 max	BS 2000 -438
Sediment	mg/kg	< 0.001	24 max	IP 415
Ash content	%m/m	< 0.010	0.01 max	BS 2000-4
Sulphur content	%m/m	1	0.10 max	BS 2000-336
Copper corrosion (3h @ 100°C)	Class	-10 -20	1	BS 2000-154
CFPP, C, Summer Winter	°C °C	zero	-4 max -12 max	BS 2000-309 BS 2000-309
Strong acid number	mgKOH/g	-	zero	BS 2000-139

Revised: April 2010



Ukay Fuels Ltd

Ukay House, Threshelfords Business Park, Inworth Road, Feering, Kelvedon, Essex. CO5 9SE
t. +44 (0) 1376 574650 f. +44 (0) 1376 571235 e. enquiries@ukayfuels.co.uk

www.ukayfuels.co.uk